

C10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2021/ 416

Dated: 16/08/2021

To,


The Principal,
Little Star Model School,
T-1/8, Budh Vihar Phase-I,
Delhi -86

Sub: Issuance of Fire Safety Certificate in r/o Little Star Model School, T-1/8, Budh Vihar Phase-I, Delhi-86.

Sir,

Kindly reference to online mail dated 12.02.2021, received in this department on the subject cited above. In this connection it is to inform you that the shortcoming already issued by this department letter of even No. 125 dated 20.02.2020 (Copy enclosed). Therefore, you are advised to submit point-wise compliance of shortcomings issued vide this department letter dated 20.02.2020 for further consideration in this matter.

Yours Faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

b/c
9

c19

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2020/125

Dated: 20/02/2020

To,

The Principal,
Little Star Model School,
T-1/8, Budh Vihar Phase-I,
Delhi -86

Sub: Issuance of Fire Safety Certificate in r/o Little Star Model School, T-1/8, Budh Vihar Phase-I, Delhi-86

Sir,


This is in reference with your letter No. LSMS-20/2019 dated 19.11.2019 received in outdoor diary no. O.D No. 25546 dated 19.11.2019, on the subject cited above. The premise was inspected by the concern nominated authority of this department in presence of Smt. Parmila Gautam (Principal) on 16.01.2020 to verify the compliance of fire prevention and fire safety measures required under the rules. Following shortcoming has been observed during inspection.

1. The width of Staircase is 1.51 & 1.37 mtr against the required width of 1.50 mtr.
2. The width of door is 0.83 mtr against the required width of one mtr.
3. 3000 ltrs Over Head water captive tank provided against the required capacity of 10,000 ltrs.
4. The required exit signage are not provided.
5. MOEFA is not provided in all exits.

In this regard as stipulated in sub Rule (1) of Rule 37 of DFS Act-2007 & Rules 2010 you are advised to apply again in Form "I" along with a certificate from Architect/ owner that all the fire prevention and fire safety measures are provided as per Rule 33 of DFS Act-2007/ Rules 2010 in the building/premise & duly filled Performa enclose herewith. The Form "I" is available on website of this department under.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours Faithfully


(Dhrampal Bhardwaj)
Dy. Chief Fire Officer
Tel:-01125156707

04
Aly