

C24

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/SZ/2021/415

Dated: 16/08/2021

To

The Principal,
Bachan Parsad Sarvodaya Kanya Vidyalaya,
Deoli, New Delhi -110080

Sub: Regarding issue of Fire Safety Certificate (FSC) in r/o Bachan Parsad Sarvodaya Kanya Vidyalaya, Deoli, New Delhi -110080


Sir,

This is in reference to with Gmail dated 26/07/2021 received of this department, on the subject cited above. In this connection, it is to inform you that concerned nominated authority of this department visited the school premises on 03/08/2021 in the presence of Mrs. Lalita Tirkey (Principal) and observed that the department issued already a shortcoming vide letter no. F.6/DFS/MS/School/2017/SZ/1395 dated 26/05/2017 has yet not been complied. (Copy Enclosed for ready reference).

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Encl: As above

Yours faithfully,



(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service



9/12

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

Fax No. 011-23412593, Ph. 011-23412225

No. F6/DFS/MS/School/2017/SZ/ 1395

Dated: 26/05/17

To

The Principal,
Bachan Parsad Sarvodaya kanya Vidyalaya,
Deoli, New Delhi-110080

Sub.- Issuing of NOC in respect of Bachan Parsad Sarvodaya kanya Vidyalaya, Deoli, New Delhi-110080

Sir,

This has reference to your letter no. 15 dated 10/04/2017 received in this office vide outdoor dairy no. 4381 dated 10.04.2017 on the subject cited above. In this connection, it is to inform you that the concerned nominated authority of this department visited the school premises on 12/05/2017 in the presence of Principal of the school and observed that the department issued already a shortcoming vide letter no.F6/DFS/MS/School/2014/2666 dated 25/11/2014 have not been rectified fully. The shortcomings observed are as below: -

1. One more additional staircase is required in "A" block,"C1" and "C2" block with the clear width of 0.75 mtr.

In view of the above shortcoming, issuance of FSC cannot be considered at this stage. You are requested to rectify the shortcoming under intimation to this department for further action in the matter.

Yours faithfully,

26/5
Vipin Kental
Chief Fire Officer

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.