

291

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No.F6/DFS/MS/School/2021/ 419

Dated 17/08/2021

To,

The Principal,
D.A.V. Public School,
Sreshtha Vihar,
Delhi-110092.

Sub:- Application for renewal of Fire Safety Certificate.

Sir,

With reference to your email ID davsreshtha@gmail.com dated 12/07/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Ms. Suhasini Khushinder Nath, Principal of school on dated 29/07/2021. The school building comprises of basement, ground plus three upper floors. During the course of inspection following observations were made:-

1. Hose reel required to be extended to entire basement area
2. Automatic sprinkler system should be extended in basement in all area.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,



(Dr. S. K. Tomar)
Dy. Chief Fire Officer



Copy to:-

The Joint Director of Education, (land & Estate)
Director of Education,
Lucknow Road, Delhi-54