GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS; DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/EH/WZ/2021 364

Dated: 23 08 2021

Mr. Saurav Vij, House No.167, Tarun Enclave, Near Deepali Chowk, Pitam Pura, Delhi-110034.

Sub: Issue of FSC in r/o M/s Ornate Inn By Blessing, Plot No.6, Community Centre, Sec-3, Delhi-110085.

Sir,

This is in reference to Online application No. 20201212144231 dated 23.12.2020 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **02.03.2021**, in presence of **Mr. Gulshan (Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. Kitchen found running on terrace in tin sheds /Temporary structure.

- 2. 10,000 ltrs Over Head captive fire water tank provided against the required capacity of 15,000 ltrs.
- 3. Second staircase is not provided in the basement.
- 4. Smoke management/ ventilation is not provided the building & staircase width is less than 1.5m.
- 5. Fire check door not provided in the building.
- 6. Exit/ lift signage are not provided.
- 7. Fire detection system is not provided in basement.
- 8. No drawings are provided in CAF, accordingly plans may be provided.
- 9. Document proof for the year of construction may kindly be provided.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 you may apply with a fresh application for grant of fire safety certificate under sub-rule (2)on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours falthfully

DIRECTOR

Ph.: 011-23414000

Vy