

C27

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/Hotel/2021/SZ/ 567
To

Dated: 24.08.2021

The Joint Commissioner of Police,
1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Issuance of NOC in r/o M/s Hotel Ambrosia, A-217, Kh. No 416, Road no 6, VPO Mahipalpur
New Delhi-110037

Sir,

This is in reference with MHA Portal ID 2021061213801 dated 12-06-2021 on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 05.08.2021 in the presence of Mr. Vijay Kumar, (Manager). During the inspection, it was observed that Basement, Ground plus three upper floors. The shortcomings observed are as below:

1. First Aid Hose reel not working.
2. Automatic sprinkler system not working.
3. Terrace level pump capacity 900 LPM not working
4. Exit signage found removed.
5. Standby electrical power supply not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service



Copy to:-

1. M/s Hotel Ambrosia, A-217, Kh. No 416, Road no 6, VPO Mahipalpur New Delhi-110037