

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/SZ/ 424

Dated: 24.08.2021

To

The Principal,
G.D. Goenka Public School (Junior),
Plot No-5 & 6, Sector-B, Pocket-8,
Vasant Kunj, New Delhi-110070

Sub: Issuance of NOC in r/o G.D. Goenka Public School (Junior), Plot No-5 & 6, Sector-B, Pocket-8, Vasant Kunj, New Delhi-110070

Sir,

This has reference to letter no GDGPS/Admin/F.No.38/2021-22 dated 08-07-2018 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 04.08.2021 in the presence of Mr. John to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Sprinkler Nozzle head found removed in the basement.
2. Terrace level Fire Pump capacity of 450 LPM not working.
3. Exit signage found removed in some places.
4. Electrical panels found installed in basement and no fire safety arrangement found provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

**(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service**

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054