

e23

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/SZ/425
To

Dated: 24.08.2021

The Principal,
Andhra Education Society Middle School
(Telugu Linguistic Minority)
Sector -2, R. K Puram, New Delhi – 110022.

Sub: Issuance of NOC in r/o Andhra Education Society Middle School (Telugu Linguistic Minority) located at Sector -2, R. K Puram, New Delhi – 110022.

Sir,

This has reference to your Outdoor diary No 1549 Dated 13/07/2021 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 29.07.2021 in the presence of Mr. Murali Krishna (Principal) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Electric Panel and store found in staircase and it shall be got removed as per the circular of Directorate of education dated 01/03/2011.
2. ELCB not provided in electrical installation.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



**(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)
DELHI FIRE SERVICE**

Copy to:-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054