

e-60

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No. F6/DFS/MS/EH/WZ/2021/355

Dated: 24/08/2021

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.

Sub:- Inspection report in r/o TSRA Tradecorp LLP Teo The Dinerroom, Shop No, 37,
Club Road, West Punjabi Bagh, New Delhi -110026.

Sir,

Please refer to your online application no.:-2021062114077 dated 24/06/2021 on the subject cited above. In this connection, it is to inform you that the premises was inspected by officers concerned of this department on 05/08/2021 in the presence of Sh. Sh. Shaan Sarin to see the functioning of fire safety equipments provided in the building. During inspection, It has been observed that the premises was comprised of Basement, Ground +3 Upper floors was issued FSC vide letter No. F6/DFS/MS/EH/WZ/2018/2035 dated 05/09/2018 for Second & Third floor only. Fire safety arrangements such as Fire Extinguishers, First Aid hose reels, Terrace Pump, Over Head water storage tank & Exit signage are provided. However the following shortcomings were observed:-

1. First-Aid Hose Reels of 30 mtrs is provided but not functional.
2. MOEFA is provided but not functional.
3. Exit signage's is found removed.
4. Terrace tank of 10,000 ltrs is provided with R.O & domestic connection.
5. Fire Check door is removed from staircases.

In view of above Shortcomings, the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The Licensing authority /statutory authority may take suitable necessary action as deemed fit.

Yours faithfully

23/08/2021
(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

ok
18/8/2021

Copy to: -

1. M/s. TSRA Tradecorp LLP Teo The Dinerroom, Shop No, 37, Club Road, West Punjabi Bagh, New Delhi -110026.
2. DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi- 110027.