

616

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/2021/ 427

Dated 25/08/2021

To,

The Principal,
Sri Guru Nanak Khalsa Sec. School,
Ahata Kidara, Bara Hindu Rao, Delhi - 06

Sub: Regarding grant of FSC in r/o Sri Guru Nanak Khalsa Sec. School, Ahata Kidara, Bara Hindu Rao, Delhi - 06 (Gr. + Mezz. + 03 Upper floor).


Sir,

This has a reference to your letter no. SGNK -278/F-88/2021 dated 26/06/2021 & Email < 1208137scholl@gmail.com on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 16/08/2021 in the presence of Mrs. Manjit Kaur and observed that shortcomings issued earlier vide letter no. F6/DFS/MS/2018/2127 dated 17.05.18 (copy enclosed) are still not complied.

Therefore, you are requested to kindly abide by our aforesaid letter for further consideration in the matter.

Encl: as above

Yours faithfully



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director (Education),
Govt. of NCT, Old Sectt.
Delhi.

C-10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/2018/ 2127

Dated 17/5/18

To,

The Principal,
Sri Guru Nanak Khalsa Sec. School,
Ahata Kidara, Bara Hindu Rao, Delhi - 06

Sub: Regarding grant of FSC in r/o Sri Guru Nanak Khalsa Sec. School,
Ahata Kidara, Bara Hindu Rao, Delhi - 06 (Gr. + Mezz. + 03 Upper floor).


Sir,

This has reference to your letter No. 75/F-88/18 dated 28/03/2018 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 28/04/2018 in the presence of Mrs. Manjit Kaur (Eng. Teacher) and the following shortcomings were observed:-

1. One additional staircase to be provided.
2. Hose reel not provided.
3. Fire pumps capacity of 450 LPM not provided.
4. Overhead water tank capacity of 10,000 liter not provided.
5. Exit signage not provided.

Hence, FSC cannot be considered at this stage.

Yours faithfully


(Sunil Chowdhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director (Education),
Govt. of NCT, Old Sectt.
Delhi.

ok
mo