

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No.F.6/DFS/MS/School/2021/NDZ/ 430

Dated:- 25/08/2021

To,

The Principal,
EDMC Pratibha Vidyalaya,
Shastri Nagar, Delhi-110031

Subject:-NOC for Shastri Nagar School from Fire Department.

Sir,

With reference to email ID mcprimaryschoolshastri1@gmail.com dated 27/07/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Sh. Ashwani, Incharge of the school on dated 17//08/2021. The school building comprises ground two upper floors. During the course of inspection following observations was made:-

1. The firefighting system which has been provided in the school building was not functional at the time of inspection.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,



(Dr. S. K. Tomar)
Dy. Chief Fire Officer

Copy to:-

The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi -92