

c/29

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No.F.6/DFS/MS/School/2021/NDZ/ 431

Dated:- 25/08/2021

To,

The Principal,
Govt. Girls Sr. Sec. School,
Rani Garden,
Delhi-110031

Subject:- Request for renewal of fire safety certificate.

Sir,

With reference to email ID 1003030hos@gmail.com dated 07/08/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Sh. O. P. Anand, Principal of the school on dated 17/08/2021. The school building comprises ground plus two upper floors. During the course of inspection following observations was made:-


1. The firefighting system which has been provided in the school building was not functional at the time of inspection.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,


23/8/21

(Dr. S. K. Tomar)
Dy. Chief Fire Officer



Copy to:-

The Joint Director of Education (Land & Estate),
Director of Education, Lucknow Road,
Delhi-110054