

C-28

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. f6/Dfs/ms/2021/449

Dated: 01/09/2021

To,
Principal,
Govt. Girls Senior Secondary School No.-3,
Sarojini Nagar, New Delhi-110023.

Subject: Inspection report of Govt. Girls Senior Secondary School No.-3, Sarojini Nagar, New Delhi-110023 (ID-1719027), from Fire Safety and means of escape point of view.

Sir,

Please refer to your letter No. GGSSSN03/FSC/2021 dated 15/07/2021 on the subject noted above, in this connection it is to inform you that the said premises was visited by the officer concerned of this department on 03/08/2021 in the presence of Smt. ASHA NAGYAL (HOS) and observed that building comprised of Ground + Two Upper Floor only.

The following shortcomings were also observed during the time of inspection:-

1. Hose Reel Hose provided but nonfunctional.
2. Fire pump of 450 LPM provided but nonfunctional.
3. Over Head Tank of 10,000 ltr provided but found nonfunctional.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (S.Z.).

o/c