

C-55

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2021/ 22

Dated: 31/8/21

To,

The Principal,
Delhi School of Professional Studies & Research (DSPSR),
Sector-9, Institutional Area, Sector-25 Rohini,
Delhi-110085.

Sub: Issue of FSC in r/o Delhi School of Professional Studies & Research (DSPSR), Sector-9, Institutional Area, Sector-25 Rohini, Delhi-110085.

Sir,


Kindly reference to online e-mail dated 17.06.2021, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **19.08.2021**, in presence of **Dr. G.S. Poplis (Director)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Pump & fire protection system provided but not functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms

Yours faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

ole
Chg