

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI-110001**

No. F6/DFS/MS/School/MN/ 441

Dated 27/08/2021

To,

The Principal,  
Guru Tegh Bahadur 3<sup>rd</sup> Centenary Public School,  
C – Block, Mansarovar Garden,  
New Delhi – 110015.

Sub: - Inspection report in respect of Guru Tegh Bahadur 3<sup>rd</sup> Centenary Public School, C – Block, Mansarovar Garden, New Delhi – 110015.


Madam,


With reference to your Email dated 26/07/2021 on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 19/08/2021 in the presence of Sh. Ravi Kumar to see the functioning of the fire safety equipments provided in the building. During inspection, it has been observed that the premises was comprised of Ground plus two upper floors was issued FSC vide letter No.F6/MS/DFS/School/2018/1910 dated 16/08/2018. Fire safety arrangements such as, Fire Extinguishers, Hose reels, Terrace pump etc. are provided. However, following shortcomings were observed: -

1. First Aid Hose reels are provided but found leakage.
2. Terrace fire pump of 450l pm is provided but not working
3. Overhead water storage tank of capacity 10,000 ltrs is found removed.
4. Exit signage's found removed.

In view of above shortcomings, the application for Renewal Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
Delhi Fire Service

  
26/08/2021

Copy to:-

The Directorate of Education Old Secretariat Delhi – 110054