

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2021/ 455

Dated: 01/09/2021

To,

The Principal,  
Govt. Girls. Sr. Sec School,  
Shahabad Daulatpur,  
Delhi-110042,

**Sub:** Issue of FSC in r/o Govt. Girls. Sr. Sec School, Shahabad Daulatpur, Delhi-110042

Sir,

This is in reference to your letter No. GGSSS/SDP/2021/12 dated 13.04.2021 received through outdoor diary no. 807 dated 13.04.2021 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **11.08.2021**, in presence of **Sh. Praveen Thakral (Vice principal)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Pumps & Fire protection provided in school are not in working condition at the time of inspection.
2. Two new blocks with name MP Hall & Multi Activity blocks are found constructed without any fire protection arrangements in the new blocks. Therefore, you are advised to provide the approved building plans on scale of 1:100 duly marked with fire protection arrangements through building authority for further consideration in this matter.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rule](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule)  
[s/http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully

(Atul Garg)  
DIRECTOR

Ph; 011-23414000

6/2  
2021