GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2021/ 453

Dated: 01 09 2021

To,

The Principal, Titiksha Public School, Sector-11, Rohini, Delhi-110085,

Sub: Issue of FSC in r/o Titiksha Public School, Sector-11, Rohini, Delhi-110085.

Sir,

Kindly reference to online e-mail dated 15.06.2021, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 11.08.2021, in presence of Sh. Rakesh Solanki (Estate Manager) to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

- 1. Staircase is provided with locking gates without key near by.
- 2. Water tank on terrace are provided with domestic connection.
- 3. Terrace pumps are provided but not functional.
- 4. One additional block found constructed making from ground to 3<sup>rd</sup> floor making building E shaped than Building plans approved by this department for C shaped building. Therefore, you are requested to provide the building plans on scale of 1:100 through building authority for further consideration in this matter.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under: <a href="http://www.delhi.gov.in/wps/wcm/connect/doit\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit\_fire/FIRE/Home/Forms">http://www.delhi.gov.in/wps/wcm/connect/doit\_fire/FIRE/Home/Forms</a>

Yours faithfully

(Dhrampal Bhardwaj) Dy.Chief Fire Officer Tel;-01123414250

of C