

246

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2021/School/ 445

Dated: 01/09/2021

To,

The Principal,
Govt Sarvodaya Bal Vidyalaya,
Pharlad Pur Banger,
Delhi-110042,

Sub: Issuance of Fire Safety Certificate in r/o Govt Sarvodaya Bal Vidyalaya, Pharlad Pur Banger, Delhi-110042.

Sir,

Kindly reference to online e-mail dated 29.06.2021, received in this department on the subject cited above. In this connection it is to inform you that the shortcoming already issued by this department letter of even No. 2920 dated 17.05.2019 (Copy enclosed). Therefore, you are advised to submit point-wise compliance of shortcomings issued vide this department letter dated 17.05.2019 for further consideration in this matter.

Yours Faithfully


(Dhrampal Bhardwaj)
Dy. Chief Fire Officer
Tel:-01123414250

me
any

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/ 2019/ 2920

Dated 17/5/2019

To

The Principal
Govt. Sarvodaya Bal Vidyalaya,
Pharlad Pur, Banger, Delhi-110042.

Sub: - Regarding issuance of fire safety certificate in r/o Govt. Sarvodaya Bal Vidyalaya, Pharlad Pur, Banger, Delhi-110042.

Sir,

Please refer to your letter no. SBV/PPB/2019/101 dated 22.02.2019 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department to verify the compliance of shortcomings/ observations already communicated earlier issued vide this department letter of even no 374 dated 25.01.2018 in the presence of Sh. V.K. Sharma Principal and the observations/ shortcomings made are as under:-

1. The width of staircase is 145cms against the required width of 150 cms.
2. Internal Hydrant provided but not functional.
3. Exit signage not provided at strategic locations in the building.

Keeping in view of above, fire safety certificate cannot be considered at this stage.

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief fire officer
Ph:-011-25104544

