

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**  
**NEW DELHI- 110001**

No.F6/DFS/MS/School/2021/SZ/ 437

Dated: 27/08/2021

To,

The principal,  
Bholi Ram Public School, E-57 to 69,  
Indira Park, Najafgarh, New Delhi-110043

Sub: - Regarding grant of NOC from fire safety point of view in r/o Bholi Ram Public School, E-57 to 69,  
Indira Park, Najafgarh, New Delhi-110043.

Sir,

Please refer to your letter no. NIL Dated-09/08/2021 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of the above-mentioned school building from fire safety point of view. During the course of inspection, the following points / shortcomings were noticed:

1. First aid hose reel not provided.
2. Fire pump having 450 LPM not provided.
3. Over head water storage tank of 10,000 ltrs not provided.
4. Exits signage's are not provided

In view of above, the school building cannot be considered for grant of fire safety certificate at this stage. Therefore you are suggested to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Sunil Chawdhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. Director of Education,  
GNCT of NCT of Delhi, Old Secretariat,  
Delhi-110054.