

C 28

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2021/ 458

Dated: 01/09/2021

To,

The Principal,
Govt. Sr. Sec. School,
Sector-21, Phase-III, Rohini,
Delhi-85.

Sub: Issue of FSC in r/o Govt. Sr. Sec. School, Sector-21, Phase-III, Rohini, Delhi-85.

Sir,

Kindly reference to online e-mail dated 19.07.2021, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **19.08.2021**, in presence of **Dr. S. S. Yadav (Principal)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Hose missing from hose box & hose reel nozzle missing.
2. Pump & fire protection system provided but not functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rule
[s/http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms)

Yours faithfully


27/07/2021
(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250
ole
Dy