

340

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2021/ 446

Dated: 01/09/2021

To,
The Principal,
P.S.M. Public School,
Pratap Vihar, Kirari Extn. Nangloi,
Delhi-86.

Sub: Issue of FSC in r/o P.S.M. Public School, Pratap Vihar, Kirari Extn. Nangloi, Delhi-86.

Sir,

This is in reference to your letter No. PSM/PV/2021/1661 dated 26.07.2021 received through outdoor diary no. 1793 dated 28.07.2021 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **12.08.2021**, in presence of **Sh. Deepak (Chairman)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Terrace Fire pump with capacity 450 & 180 LPM provided but not functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule
[s/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully


(Dhrampal Bhardwaj)
Dy. Chief Fire Officer
Tel:-01123414250

etc
ay