

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/2021/SZ/ 440  
To

Dated: 27/08/2021

The Principal,  
Jose Marti Sarvodaya Vidyalaya,  
R. K Puram, Sector- 12,  
New Delhi 110022.


**Sub:** Regarding issue of Fire Safety Certificate (FSC) in r/o Jose Marti Sarvodaya Vidyalaya,  
R. K Puram, Sector 12, New Delhi.

Sir,

This is in reference to Gmail dated 10/08/2021 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 19/08/2021 and observed that the shortcoming intimated vide letter of even no. 198 dated 07/04/2021 has yet not been complied. (Copy Enclosed for ready reference).

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Sunil Chawdhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Copy to:-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.

235

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/2021/SZ/ 352

Dated: 16/ 7/2021

To

The Principal,  
Jose Marti Sarvodaya Vidyalaya,  
R. K Puram, Sector- 12,  
New Delhi 110022.

**Sub:** Regarding issue of Fire Safety Certificate (FSC) in r/o Jose Marti Sarvodaya Vidyalaya,  
R. K Puram, Sector 12, New Delhi.

Sir,

This is in reference to Gmail dated 30/06/2021 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 07/07/2021 and observed that the shortcoming intimated vide letter of even no. 198 dated 07/04/2021 has yet not been complied. (Copy Enclosed for ready reference).

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Sunil Chawdhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Copy to:-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/SZ/ 198

Dated: 07/04/2021

To

The Principal,  
Jose Marti Sarvodaya Vidyalaya,  
R. K Puram, Sector 12,  
New Delhi - 110022

Sub.:- Renewal of Fire Safety Certificate in r/o Jose Marti Sarvodaya Vidyalaya, R. K Puram, Sector 12, New Delhi - 110022


Sir,

This has reference to your letter no nil dated 08/03/2021 on the subject cited above. In this connection, the said school premises have been inspected by concerned nominated of this department on 24/03/2021 in the presence of Sh. Karuna Sree (Principal). During the inspection it was observed that school is comprised of Ground plus two upper floors, Except Auditorium. The shortcomings observed are as below.

1. First Aid Hose Reels are not working.
2. Terrace level pump capacity 450 LPM provided but not working.
3. Overhead tank capacity 10,000 ltrs found empty.
4. Exit signage found removed.

In view of above shortcomings, renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcoming under intimation to this department for further action in the matter.

Yours faithfully,



(Sunil Chawdhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054