

631

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2021/SZ/ 464

Dated: 03/09/2021

To,

The Principal,
Govt. Girls Sr. Sec. school No.1,
Najafgarh, New Delhi-110043.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Govt. Girls Sr. Sec. School no.-1, Najafgarh, New Delhi-110043.

Sir,

Please refer to your letter no. Nil Dated- 01/08/2021 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 21/08/2021 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Rajender (Estate Manager) was present and it was observed that the school building is comprised of ground plus three upper floors (Main Block) & primary block having ground plus one upper floor and have following shortcomings.

1. First aid hose reel provided but not functional.
2. Fire pump having 450 lpm output provided but not functional & auto mode.
3. Overhead water tank capacity of 4000 liters provided instead of 10,000 ltrs.
4. Exits signages are not provided.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

(Sunil Chawdhary)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Principal, Govt. Girls Sr. Sec. School no.-1, Najafgarh, New Delhi-110043.
2. The Director of Education, Govt of NCT of Delhi, Old Secretariat, New Delhi-110054. (with a request to take further action as school does not have fire NOC)