

C18

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F6/DFS/MS/School/2021/ 468

Dated 06/09/2021

To,
The Principal,
EDMC Primary School,
Tahirpur Village,
Delhi 110095

Sub:- Regarding Issuance Fire Safety Certificate.

Sir,

This is in reference to your Email No. hos1152010@gmail.com dated 06/04/2021 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned EDMC Primary School from fire safety point of view in presence of Mr. Avdesh Kumar Singh, Principal of the School on dated 02/07/21. During the course of inspection it was observed that the school was issued Fire Safety Certificate for ground plus one upper floor vide letter No. F6/DFS/MS/School/2017/1853 dated 22/12/17. The school management has constructed a new building comprised of ground plus two upper floors. The following points / shortcomings were noticed in the building comprised of ground plus two upper floors.

1. Only 04 fire extinguishers provided in place of 10 fire extinguishers as required.
2. First-Aid hose reels (01 nos.) not provided at each floor as required.
3. A fire pump having 450 LPM output at 40 meters head not provided.
4. Over Head water storage tank 10,000 liters capacity not provided

In view of above, the building can not be considered for grant of fire safety certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully


(Atul Garg)
Director

Copy to:-

The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi 92