

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/SZ/2021/ 466

Dated: - 03/09/2021

To,

The Chairman,  
Bajaj Public School, Street No.- 04,  
Prem Nagar, New Delhi- 110008.

Sub.- Regarding renewal of Fire Safety Certificate in r/o Bajaj Public School, Street No.- 04,  
Prem Nagar, New Delhi- 110008.

Sir,


Please refer to your e-mail dated 07.08.2021 received through e-mail ID [bajajpublicschool1@gmail.com](mailto:bajajpublicschool1@gmail.com) on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department on 19.08.2021 in presence of Sh. M.M Bajaj, Chairman, to check the functionality of fire safety arrangements.

During the inspection, it was also observed that the school building is comprised of basement, ground plus two upper floors. The upper floors are served by 02 nos. of staircases having width 1.15 & 1.10 mts up to terrace and basement severed by 02 nos. of staircases having width 1.15 & 0.80 mts. Fire safety arrangement such as fire extinguishers, hose reel, overhead water tank etc. found provided. However following shortcomings were observed: -

1. Terrace pump 450 Lpm found provided but not functional.
2. Exit signages found removed.
3. Overhead water storage tank capacity 1000 lts is found provided against required 10,000 lts exclusively for firefighting purposes.

In view of the above, 'Fire Safety Certificate' cannot be renewed at this stage. You are requested to rectify the above-mentioned fire safety arrangements under intimation to this department.

Yours faithfully



(Sunil Chaudhary)  
Dy. Chief Fire Officer  
South Zone

01/9  


Copy to: -

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi- 110054.