

C-32

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001**

No. F6/DFS/MS/School/2021/SZ/ 463

Dated: 03/09/2021

To,

Assistant Engineer (E),
Edu. Sub-Divn M1-1,(N),
PWD, ITI Campus, Pusa, New Delhi-110012.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Sarvodaya Kanya Vidyalaya, B-Block, Janakpuri, New Delhi-110058.

Sir,

Please refer to your letter no. 54 (SPS School) PWD Edu. Sub-Divn M1-1(N)/2021-22/93 Dated- 26/07/2021 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 18/08/2021 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Ved Prakash (Estate Manager) was present and it was observed that the school building is comprised of ground plus three upper floors (New Block) and have following shortcomings.

1. First aid hose reel not provided.
2. Fire pump having 450 lpm output 40 m head not provided at terrace.
3. Exits signages are not provided.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)
Director

Delhi Fire Service

9/9/21

Copy to:-

1. The Principal, Sarvodaya Kanya Vidyalaya, B-Block, Janakpuri, New Delhi-110058.
2. The Director of Education, Govt of NCT of Delhi, Old Secretariat, New Delhi-54
(with a request to take further action as school does not have fire NOC)