

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/School/2021/ 472

Dated:-07/09/2021

To

The Principal,
Mother Marry Public School,
292-B, Main Road, Mandawali, Delhi-92.

Sub: Regarding Renewal of FSC in r/o Mother Marry Public School, 292-B, Main Road, Mandawali, Delhi-92.

Sir,

This has reference to your email dated 16/08/2021 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 31/08/2021 in the presence of Mr. Gaurav Verma and observed that following shortcoming was observed :-

1. Pump provided but not functional.
2. Hose reel hose/Hydrant provided but not functional.
3. Exit signage not provided.

Hence, renewal of Fire Safety Certificate can not be considered at this stage.

Yours faithfully



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Director (Education),
EDMC, 419, Udyog Sadan,
Patparganj Industrial Area, Delhi - 92.

