GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2021/ 477

Dated: 08/09/2021

To.

The Owner. Arya Veer Model School, A-38, Badli Extension, Delhi-110042.

Sub: Renewal of Fire Safety Certificate in r/o Arya Veer Model School, A-38, Badli Extension, Delhi-110042.

Sir,

Kindly reference to online mail dated 27.07.2021, received in this department on the subject cited above. In this connection it is to inform you that the shortcoming already issued by this department letter of even No. 275 dated 15.05.2021 (Copy enclosed). Therefore, you are advised to submit point-wise compliance of shortcomings issued vide this department letter dated 18.05.2021 for further consideration in this matter.

Yours Faizhfully

(Dhrampal Bl

Dy.Chief Fire Officer Tel;-01123414250

12021

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2021/ **27**5

Dated: 18/5/2/

To,

The Owner, Arya Veer Model School, A-38, Badli Extension, Delhi-110042.

Sub: Renewal of Fire Safety Certificate in r/o Arya Veer Model School, A-38, Badli Extension, Delhi-110042.

Sir.

Kindly reference to online mail dated 20.09.2020, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department in presence of 27.01.2021 on Sh. Mahender Pal Manchanda (Owner) to verify the compliance of fire prevention and fire safety measures required under the rules. The renewal of FSC is rejected under sub rule (3) of Rule 37, in the view of reasons mentioned below:

- 1. One staircase found removed in basement.
- 2. Fire pump was not in working condition at the time of inspection.
- 3. Height verification from North MCD be submitted in letter department for further consideration

In this regard as stipulated in sub Rule (1) of Rule 37 of DFS Act-2007 & Rules 2010 you are advised to apply again in Form "J" along with a declaration from owner/occupier on Form "K" as required under Rule 38 that all the fire prevention and fire safety measures provided in the building/premise are in best repairs. The web links for DFS Act-2007/ Rules 2010 & Form "J" & "K" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours Faithfully

(Dhrampal Bhardwaj) Dy.Chief Fire Officer Tel;-01123414250

Of C