

C-6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2021/SZ/ 476

Dated: 08/09/2021

To,

The Principal,
Lawrence Public School,
C-3 Block, Janakpuri, New Delhi-110058.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Lawrence Public School at C-3 Block, Janakpuri, New Delhi-110058.

Sir,

Please refer to your letter no. LPS/2021/2042 Dated- 14/07/2021 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school to verify the fire safety arrangements in accordance with the rules. At the time of inspection Mr. Sanjay Kumar (Admin) was present and it was observed that the school building is comprised of ground plus three upper floors and have following shortcomings.

1. Fire Extinguishers provided but not functional.
2. First aid hose reel provided but not functional.
3. Down comer system provided but not functional.
4. Fire pump having 450 lpm output not provided & auto mode at terrace.
5. Over head water storage tank 2,000 liters provided in place of 10,000 liters.
6. Exits signage's are not provided.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

(Atul Gaig)

Director

Delhi Fire Service

9/9/21

Copy to:-

The Director of Education,
Govt of NCT of Delhi, Old Secretariat,
New Delhi-110054.

(with a request to take further action as school does not have fire NOC)