

916

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No.F6/DFS/MS/School/2021/NDZ/ 481

Dated: 09/09/2021

To,

The Principal,
Dev Public School,
Street No. 4, East Rohtas Nagar,
Shahdara, Delhi-110032

Subject:- Request for issuing a Fire Safety Certificate.

Sir,

With reference to your email ID devpublicschool2011@gmail.com dated 16/08/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view on dated 26/08/2021 in presence of Sh. Adesh Kumar Sharma, Manager. The school building comprises of ground plus three upper floors. During the course of inspection following observation was made:-

1. The premises is not accessible to fire engines.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage.

Yours Faithfully,



(Dr. S. K. Tomar)
Dy.Chief Fire Officer

