

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/School/2021/ 482

Dated: 09/09/2021

To,

The Principal,  
Govt. Girls Sr. Sec. School,  
Jafrabad Extension, Delhi-110032

**Subject:- Fire NOC letter 2021.**

Sir,

With reference to email ID No. [1105114hos@gmail.com](mailto:1105114hos@gmail.com) dated 27/07/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Ms. Rashmi Rani, principal, of the school on dated 26/08/2021. The school building comprises of ground plus two upper floors. During the course of inspection following observations were made:-

1. A fire pump with 450 liters per minute discharge at 40 meters head (4kgf/sq.cm.) is required to be provided at terrace level.
2. An overhead water tank having 10,000 liters is required to be provided exclusively for fire fighting systems.
3. Hose reels containing 30m of length and 20mm bore terminating in to a shut-off nozzle of 5mm outlet connected to the pump shall be provided for every 1000sqm. of covered area subject to a minimum of one hose reel per floor of the school building, are required to be provided.
4. Exit signs are required to be provided in the school building at all exits.
5. Sanctioned/Completion plans or as built plans (on the scale of 1:100 having details of height/covered area, year of construction/conversion of occupancy duly marked with fire and life safety arrangements as stipulated under Rule 33 of Delhi Fire Service Act of Rules 2010) through building/local authority, in case sanctioned/completion plans are not available.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,



(Dr. S. K. Tomar)  
Dy. Chief Fire Officer



Copy to:-

The Dy. Director of Education,  
B-Block, Yamuna Vihar,  
Delhi-110053