

c/33

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/School/2021/NDZ/ 483

Dated: 09/09/2021

To,

The Vice Principal,
Govt. Sarvodaya Kanya Vidyalaya,
Krishna Nagar, Delhi-110051

Subject:- Updating of Fire Safety Certificate Building ID. 1003119.

Sir,

With reference to email ID 1003036hos@gmail.com dated 25/08/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school on 26/08/2021 in presence of Ms. Mamta, Vice Principal, It was noted that the shortcomings issued vide letter No F.6/DFS/MS/School/2018/NDZ/4787 dated 26/11/2018 & No. F.6/DFS/MS/School/2021/NDZ/166 dated 30/03/2021 have not been complied as yet (The Copy of the same is enclosed for your reference).

Therefore, you are requested to rectify the above shortcomings communicated vide above mentioned letter under intimation to this office for further action.

Yours Faithfully,


7/9/21

(Dr. S. K. Tomar)
Dy. Chief Fire Officer



429

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/School/2021/NDZ/ 166

Dated: 30/03/2021

To,

The Vice Principal,
Govt. Sarvodaya Kanya Vidyalaya,
Krishna Nagar, Delhi-110051.

Subject:-Request issue of NOC Fire Safety Certificate School ID-1003036 Building ID- 10031191.

Sir,

With reference to your letter No. GSKV/KN/2020-2021 dated 08/02/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school on 18/03/2021 in presence of Mrs. Mamta, Vice Principal, it was noted that the shortcomings issued vide letter No F.6/DFS/MS/school/2018/NDZ/4787 dated 26/11/2018 have not been complied as yet (The Copy of the same is enclosed for your reference).

Therefore, you are requested to rectify the above shortcomings communicated vide above mentioned letter under intimation to this office for further action.

Yours Faithfully,


28/3/21

(Dr. S. K. Tomar)
Dy. Chief Fire Officer



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/2017/3424

Dated: 18/12/17

To,

The Principal,
Govt. Sarvodaya Kanya Vidyalaya,
Krishna Nagar, Delhi.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Govt. Sarvodaya Kanya Vidyalaya, Krishna Nagar, Delhi.

Sir/Madam,

Please refer to your letter no. GSKV/KN/17 Dated- 11/10/16, on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out inspection in presence of Kiran uppal Vice Principal from Fire/Life safety points of view. During inspection it was observed that The school has already been issued FSC for G+1 upper floor vide letter F6/DFS/MS/School/2014/NDZ/1320 dated 21/10/14. but has added second floor now.

The following shortcomings were observed:-

1. First Aid Hose reels are not Provided.
2. Fire pump of 450 LPM is not provided.
3. Over head tank of 10,000 liter for Fire Purpose.
4. Exit Signages are not Provided.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

Vipin Kental
15/12

(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

Copy to:-

The Joint Director of Education
(Land & Estate)
Directorate of Education, Lucknow Road, Delhi-54.

9/12/17