

C41

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2021/ 479

Dated 28/09/2021

To,

The Principal,
Sarvodaya Kanya Vidhalaya No 2,
Palam Village, New Delhi – 110045.

Subject: Issuance of Fire Safety Certificate in respect of Sarvodaya Kanya Vidhalaya No 2, Located at Palam Village, New Delhi – 110045.(School Id-1821015)

Sir,

4319/21

Please refer to your Email Dated-12/08/2021 on the subject captioned above. In this connection you are advised to apply after complying the shortcomings communicated vide letter no. F6/DFS/MS/School/2018/SZ/1941 dated 10/05/2018 (Copy enclosed).

The preemies shall be on the risk and cost of owner/ occupants till the compliance of shortcomings.

In view of the above FSC from fire safety point of view cannot be considered at this stage.

Yours faithfully,

Enclosed: - As above



(Sunil Chaudhary)
Dy.Chief Fire Officer,
Delhi Fire Service

Copy to :- Directorate of Education Old Secretariat Delhi – 110054.

4319/21

C-23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F6/DFS/MS/School/2018/SZ /1941

Dated: 10/05/18

To,

Head of School,
Sarvodaya Kanya Vidhalaya No.2,
Palam Village, New Delhi-110045.

Subject:- Renewal of Fire Safety Certificate from Fire safety point of view in r/o Sarvodaya Kanya Vidhalaya No.2, Palam Village, New Delhi-110045.

Madam,




This is in reference to your letter no. SKV/PV/ND/2018/1439 dated 5.2.2018 on the subject cited above. In this connection, it is to inform you that above said school building have been inspected by the officer concerned of this department on 6.4.2018 in presence of Mrs. Pramila Varshnaya (HOS) & Sh. Gajraj Singh (Estate manager) to see workability of fire fighting system provided therein.

During the course of inspection following shortcomings have been observed:

1. Fire pump at terrace level is provided but not operational.
2. Water storage tank for firefighting at terrace level found empty.

In view of the above mentioned shortcoming fire safety certificate cannot be granted at this stage. You are advised to rectify above shortcomings under intimation to this department for taking further necessary action.

Yours Faithfully,


(Vipin Kental)
Chief Fire Officer



Copy to:-

1. The Director (Education), GNCT of Delhi, Old Secretariat, Delhi-110054.