

C55

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2021/SZ/ 480

Dated: 09/09/2021

To,

The Principal,
Sat Saheb Public School, 101, C-Block,
Som Bazar, Nanhey Park, Uttam Nagar, New Delhi-110059.

Sub:- Regarding Issuance of Fire Safety Certificate in r/o M/s Sat Saheb Public School, 101, C-Block, Som Bazar, Nanhey Park, Uttam Nagar, New Delhi-110059.


Sir,

This is in reference to your letter No. S/S/P/S dated 17/07/2021 on the subject cited above. In this connection, it is to inform you that the inspection of above said building has been carried out by officers concerned of this department on 31/08/2021 in presence of Smt. Vidhi Dabas (Principal). During the course of inspection it was observed that the building is comprised of ground floor plus three upper floors. The following shortcomings were observed:-

1. An additional first aid hose reel system shall be provided as single hydrant is not covering entire floor.
2. Fire pump having 900 lpm provided but not functional.
3. Exit signage's were found removed.

Keeping in view of above, the building cannot be considered for issuance of fire safety certificate, at this stage. Therefore you are advised to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours Faithfully


(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service



Copy:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.