

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No.F.6/DFS/MS/School/2021/NDZ/ 484

Dated:- 10/09/2021

To,

The Principal,
Green Land Model School,
A-92, Shastri Park,
Delhi-110053

Subject:- Application for renewal of fire safety certificate.

Sir,

With reference to email greenlandmodelschool1105195@gmail.com dated 18/07/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Mr. Ajay Kumar Parashar on dated 25/08/2021. The school building comprised ground plus three upper floors. During the course of inspection following observations was made:-

1. The firefighting systems which have been provided in the school building, were not functional.
2. Alternate exit passway found blocked and inaccessible.
3. Exit signages are required to be provided at all exits.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,



(Dr. S. K. Tomar)
Dy. Chief Fire Officer

Copy to:-

The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi- 110053.

g/c 