

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F.6/DFS/MS/NDZ/2021/ 1876

Dated:- 15/09/2021

To

Sh. Jagdish Narayan
Estate Manager, Adishwar Apartment
34, Firozshah Road, New Delhi - 110001.

Sub:- Regarding renewal of FSC in r/o Adishwara Apartment, 34, Firozshah Road, New Delhi.


Sir,

This has a reference to your e-mail 34fzhrd@gmail.com dated 08.08.21 on the subject cited above. In this regard, it is to inform you that one side 06-meter approach road is required to be provided to the building as provided at the time of earlier/last renewal of FSC.

In view of above, it is requested to comply the same and also remaining shortcomings as issued vide letter no. F6/DFS//MS/NDZ/2020/2963 dated 04.12.2020, for further necessary action.

Yours faithfully

Encl: as above


(Atul Garg)

DIRECTOR
Delhi Fire Service

Copy to:

The Chief Architect, NDMC, New Delhi.