

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/SZ/2021/ 495

Dated: 15/09/2021

To

The Principal,
Kendriya Vidyalaya No.- 03,
Ring Road, Naraina,
New Delhi.

Sub.: - Regarding renewal of Fire Safety Certificate in r/o Kendriya Vidyalaya No. - 03, Ring Road, Naraina, New Delhi.

Sir,

Please refer to your Form letter F.No.1411/Fire Safety/K.V-3/D.C/2021-22/83 dated 10.08.2021 on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department in presence of Ms. Sushila Sharma, Vice Principal of the School, on 07.09.2021 to check the status of the shortcomings pointed out by this department vide letter No. F.6/DFS/MS/School/SZ/2020/3148 dated 25.07.2018 (copy enclosed), but no improvement was observed as seen during the course of inspection and this department has already issued a letter in this matter vide this office letter No. F.6/DFS/MS/School/SZ/2020/133 dated 21.02.2020.

In view of the above, 'Fire Safety Certificate' cannot be renewed at this stage. You are requested to rectify the above-mentioned fire safety arrangements under intimation to this department.

Yours faithfully

Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Asstt. Commissioner, Kendriya Vidyalaya Sangathan, Delhi Region, JNU Campus, New Mehrauli Road, New Delhi- 67. -for information please.

C-48

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/SZ/2020/ 133

Dated: 21/02/2020

To

The Principal,
Kendriya Vidyalaya No.- 03,
Ring Road, Naraina,
New Delhi.

Sub.-: Regarding renewal of Fire Safety Certificate in r/o Kendriya Vidyalaya No. - 03, Ring Road, Naraina, New Delhi.

Sir,

Please refer to your Form 'J' dated nil on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department in presence of Sh. Praveen Sharma, Principal of the School, on 16.01.2020 to check the status of the shortcomings pointed out by this department vide letter No. F.6/DFS/MS/School/SZ/2020/3148 dated 25.07.2018 (copy enclosed), but no improvement was observed as seen during the course of inspection.

In view of the above, 'Fire Safety Certificate' cannot be renewed at this stage. You are requested to rectify the above-mentioned fire safety arrangements under intimation to this department.

Yours faithfully

[Handwritten Signature]
19/2/2020

Dy. Chief Fire Officer (SZ)
Delhi Fire Service

18/2

Copy to: -

1. The Asstt. Commissioner, Kendriya Vidyalaya Sangathan, Delhi Region, JNU Campus, New Mehrauli Road, New Delhi- 67. -for information please.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/SZ/2018/

3148

Dated: - 25/07/18

To

The Principal,
Kendriya Vidyalaya No.- 03,
Ring Road, Naraina,
New Delhi.

Sub.: - Regarding renewal of Fire Safety Certificate in r/o Kendriya Vidyalaya No. - 03, Ring Road, Naraina, New Delhi.

Sir,

Please refer to your Form 'J' dated nil on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department in presence of Sh. Narander Bist, Office Superintendent, on 12/07/2018 to check the fire safety arrangements.

During the inspection, it was also observed that the school building is comprised of ground plus one upper floor, served by 05 nos. of staircases having width 2.0, 1.55, 1.40, 1.40 & 1.40 mts from ground to first floor. Fire safety arrangement such as fire extinguishers, exit signages etc. found provided. However, following shortcomings were observed: -

1. Alternate exit door of width 1.0 mt. of each classrooms having capacity 45 or more students is required.
2. Exit signage found removed.

In view of the above, 'Fire Safety Certificate' cannot be renewed at this stage. You are requested to rectify the above-mentioned fire safety arrangements under intimation to this department.

Yours faithfully

(VIPEN KENTAL)

CHIEF FIRE OFFICER

Copy to: -

1. The Asstt. Commissioner,
Kendriya Vidyalaya Sangathan,
Delhi Region, JNU Campus,
New Mehrauli Road, New Delhi- 67.

for information please.