

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110001

No.F6/DFS/MS/Mercantile/2021/SZ/

1835

Dated:

10/09/2021

To,

The Manager,
P.P.Buildwell Pvt. Ltd.,
Plot No.P-1,P.P.trade Centre, Netaji Subhash Place,
Pitam Pura, Delhi-110034.

Sub: - Regarding grant of NOC from fire safety point of view in r/o P.P.Buildwell Pvt. Ltd.,
Plot No.P-1,P.P.trade Centre, Netaji Subhash Place, Pitam Pura, Delhi-110034.

Sir,

Please refer to your letter no. NIL Dated -24/07/2021 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of the above-mentioned mercantile building from fire safety point of view. The premises are comprised of two basements, ground floor plus ten upper floors. During the course of inspection, the following points / shortcomings were noticed: -

1. Electrical shafts are not properly sealed.
2. First aid hose reel provided but not functional
3. Automatic fire detection and alarming system provided but not functional
4. Mechanical ventilation of basement not functional.
5. Internal hydrants provided but not functional
6. Yard hydrants provided but not functional
7. Standby fire pump not functional & other pumps are not on auto mode.
8. Exits signage's are not properly installed.

In view of above, the building cannot be considered for grant of fire safety certificate at this stage. Therefore you are suggested to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours faithfully


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

AK