

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**

No. F. 6. / DFS / MS / BP / 2021/Hospital/ 1812

Dated: 08/09/2021

To,

The Executive Engineer,
Health Project Division (West),
Public Works Department,
Sector - 9, Dwarka, New Delhi- 110077.

Sub :- Construction of proposal New Building Block (B+G+6 Floors) for expansion of Rao Tula Ram Memorial Govt. Hospital, Jaffarpur, New Delhi.


Sir,

Please refer your letter No. 54(36)(RTRM)/Health Project Division (West)/PWD/2021/961 dated 16/08/2021 on the subject cited above. In this connection it is to inform you that the matter has been examined and observed that earlier this department had issued fire safety guidelines for the proposed aforesaid Hospital vide letter No. F.6/DFS/MS/BP/2016/Hospital/168 dated 15.07.2016 with 27 meter height. Now the height is proposed to be increased to 30.75 meter. The revised height does not affect the fire safety measures as recommended vide above letter dated 15.07.2016 except underground fire water tank. Earlier the underground fire water tank of 1,50,000 liters capacity was recommended as per NBC-Part-4, 2005, whereas, as per NBC-Part, 4-2016 the capacity of underground fire water tank is 2,00,000 liters. No other changes except refuge area shall take place. Further, the provision of refuge area is also needed at sixth floor level i.e. 26.55 meter.

The proposal is accepted subject to following conditions:

1. Refuge area shall be provided on sixth floor in accordance with clause 9.3.6 & 9.3.7 of UBBL-2016.
2. Capacity of underground fire water tank shall be increased to 2,00,000 liters.
3. Other life and fire safety measures, recommended vide No. F.6/DFS/MS/BP/2016/Hospital/168 dated 15.07.2016 shall be complied with.

Yours faithfully


7/9/2021

(Virendra Singh)
Dy. Chief Fire Officer
Ph. 011-23412225

