

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/NDZ/2021/ 1899

Dated: 17/ .09.2021

To

Mr. Narayan Singh,
Addl. Vice President – Quality,
33, KV Grid Car Bazar, Shakarpur,
Delhi-110092.

Sub:- Regarding issuance of Fire Safety Certificate in r/o Staff Colony (BSES Urja Vihar) at Mandawali, Patparganj, Delhi.


Sir,

This has reference to your email dated 02/08/2021 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 24/08/2021 in the presence of Mr. Narayan Singh(Addl. Vice President) and the following shortcomings were observed :-

1. 06 meter access around the building not available.

Hence, Fire Safety Certificate can not be considered at this stage.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service