

C25

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No.F6/DFS/MS/BNQT/2021/NDZ/ 398

Dated: 14/09/2021

To,

Sh. Nirmal Jain,
Surahi Banquet Manakchand Celebrators,
Ground Floor G-30, 31, G.F. Unity One Mall,
CBD Ground, Shahdara, Delhi-110032

Subject: Renewal of Fire Safety Certificate.

Sir,

With reference to your online letter No. 2021040512325 dated 19/04/2021 on the subject cited above, it is informed that officer concerned of this department inspected the Surahi Banquet Manakchand Celebrators from fire safety point of view in presence of Ms. Geeta Chadha, Manager on dated 30/07/2021. During the course of inspection following observations were made:-

1. One number of exit door of width 1.5 meter is required to be provided in the banquet.
2. Automatic Sprinkler System is required to extended in the entire banquet area.
3. Exit signages are required to be provided in the banquet at all exits.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,


13/9/21

(Dr. S. K. Tomar)
Dy. Chief Fire Officer