

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/SZ/2021/ 502

Dated: 20/09/2021

To,

The Principal,  
Pt. Ram Chander Vidhya Niketan,  
Village Bharthal,  
New Delhi - 110077

Subject: Renewal of Fire Safety Certificate iro Pt. Ram Chander Vidhya Niketan, Located at Village Bharthal, New Delhi – 110077.

Sir,

Please refer to your letter no. Email dated 23/08/2021 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the team of officers from this department on 08/09/2021 for the renewal of fire safety certificate. During course of inspection the following shortcomings were observed:

1. Hose reel Hose found nonfunctional
2. Automatic Sprinkler System in basement found nonfunctional.
3. Internal hydrants found nonfunctional.
4. Terrace pumps found nonfunctional and not in auto mode.

In view of the above shortcomings Fire Safety Certificate can not be considered at this stage.

You are requested to comply the abovementioned shortcomings under intimation to this department.

Yours faithfully,



(Sunil Chaudhary)  
Dy. Chief Fire officer  
Delhi Fire Service

Copy to;-Directorate of Education Old Secretariat Delhi – 110054

