

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI -110001**

F6/DFS/MS/ NDZ/ 2021/ 1917

Dated: 20/09/2021

To,

The Authorized Signatory,
Mercantile House Flat Owner Association,
Flat 612, Mercantile House,
15, K.G, Marg, New Delhi.

Subject:- Regarding renewal of FSC in r/o Mercantile House at 15, K.G. Marg, New Delhi.

Sir,

This has reference to your letter No. nil dated 17/08/21 on the subject noted above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 09/09/2021 in the presence of Sh. Aalok (Estate Manager) and the following shortcomings were observed:-

1. Entrance gate obstructed by branches of tree which require trimming for easy access.
2. Fire check doors found broken at some floors.
3. Electric Shafts/openings are not sealed properly and open and loose wiring to be secured properly.
4. Exhaust in basement for smoke management found nonfunctional.
5. Detectors found nonfunctional at some places.
6. Hose reel provided in basement is not covering entire area, either to be extended or provided additional one.
7. Sprinklers covered by POP required to be opened, to make them functional.

In view of above shortcomings, request for renewal of fire FSC is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully,

(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to:-

1. ✓ The Chief Architect , NDMC , Palika Kendra , New Delhi