

c.21

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/School/2021/NDZ/ 501

Dated: 20/09/2021

To,

The Principal,
E.D.M.C. Primary School,
West Vishwas Nagar,
Shahdara South-Zone, Delhi- 110032

Subject:- Regarding Fire Safety Certificate (NOC) .


Sir,

With reference to your email ID hos1051170@gmail.com dated 05/08/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Sh. Ashu Parkash Caretaker/Guard of the school on dated 19/08/2021. The school building comprises of ground plus three upper floors. During the course of inspection following observations were made:-

1. An overhead water tank having 10,000 liters capacity is required to be provided exclusively for firefighting systems.
2. A fire pump with 450 liters per minute discharge at 40 meters head (4kgf/sq.cm.) is required to be provided.
3. The firefighting system (hose reel) which has been provided in the school building, was not functional at the time of inspection.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above mentioned fire safety arrangements under intimation to this office for further necessary action.

Yours Faithfully,


(Atul Garg)
Director

Copy to:-

The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi -92