

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/EH/2021/SZ/ 1918
To

Dated: 20/09/2021

The Dy. Health Officer,
SDMC, South Zone,
Green Park, Delhi 110016

Sub: - Issuance of No Objection Certificate in r/o M/s CAFÉ VSB (A unit of VSB Studio) Shop no 7, Plot No 2, Square 1 Mall, Commercial Complex District Center, Saket Delhi 110017


Sir,

This has reference to your Online No. 2021081117459 dated 11/08/2021 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 06.09.2021 in the presence of Mr. Selvey (Manager) to verify the fire safety measures installed in the building. Accordingly fire safety arrangements were tested / checked and found following observation.

- 1 There is one door having width of 1.0 mtr against the required of two having width of 1.50 mtr each respectively.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR

Copy to:-

1. M/s CAFÉ VSB (A unit of VSB Studio) Shop no 7, Plot No 2, Square 1 Mall, Commercial Complex District Center, Saket Delhi 110017