

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/SZ/2021/504

Dated: 21 / 09 / 2021

To

The Principal,
Sarvodaya Vidyalaya No 3,
Sector 7, R.K Puram,
New Delhi 110022


Sub: - Regarding Issue of fire Safety NOC r/o Sarvodaya Vidyalaya No 3, Sector 7, R.K Puram,
New Delhi 110022 (ID 1719022)

Sir,

This has reference to your Gmail dated 07/09/2021, on the subject cited above. In this connection, in this connection, it is to inform you that the above mentioned site was visited by the officer concerned of this department on dated 13/09/2021 in the presence of Mrs. Kusum Suman (Vice Principal) and observed that the department issued FSC vide letter no F6/DFS/Ms/School/2015/1564 dated 28/08/2015 (ground plus three upper floor one block & ground plus one upper floor, one block). Now the school management demolished ground plus one upper floor block and constructed two new blocks of ground plus two upper floors with one hall at old block of ground plus three. There was a material change in school building. So you have to submit the Sanctioned / completion plans in a scale of (1:100) with covered area and height of the building, to adjudge the applicability of fire prevention & fire safety measures.

In view of above, renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to submit required documents /information for further action in the matter.

Yours faithfully



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054.