

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2021 / 503

Dated: 21/09/2021

To

The Vice Principal/HOS,
Mazharul Islamic Sec. School,
1436, Chhatta Nawab Sahab, Farash Khana, Delhi-06.

Sub :-Regarding issuance of Fire Safety Certificate in r/o Mazharul Islamic Sec. School, 1436,
Chhatta Nawab Sahab, Farash Khana, Delhi-06.


Sir,

With reference to your letter no. nil dated 10.09.2021 on the subject cited above. It is informed that the School building has been inspected by the Assistant Divisional Officer (SPM) from this department on 10.09.2021 in the presence of Mr. Imteyaz Ahmad, (Vice Principal/HOS), and it was observed that the school building is comprised of ground + 01 upper floors. The following shortcomings were observed during the inspection.

1. School is not accessible to fire engines as approach road width is less than 6 meters.
2. The width of main staircase is 0.70 m therefore an additional staircase of minimum 75 cms width is required.
3. Exit signages are not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(A.D. Garg)
Director,

Tel: 011-23414000.

etc 
20/9/21

Copy to:-

The Dy. Directorate of Education,
Zone XXVII, District Central, Directorate of Education, GNCT of Delhi, Jhandewalan, New Delhi.