

C-45

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZ/ 641

Dated:-22/09/2021

To,

The Manager  
M/S Shiva Dx. Guest House 4623, Shora  
Kothi, Main Bazar, Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Shiva Dx. Guest House 4623,  
Shora Kothi, Main Bazar, Pahar Ganj, New Delhi.

Sir,

This has reference to on line ID No. 2021082418755 dated 24/08/2021, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 14/09/2021 in the presence of Manager and following shortcomings were observed: -

1. Hose reel found nonfunctional.
2. Fire extinguishers are due for refilling
3. MOEFA not provided.
4. Terrace pump found nonfunctional (not on auto start mode).
5. Alternate power supply found nonfunctional.

You are also requested is submit compliance of notification dated 27.05.19 latest by 30.09.2021.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

  
2019/21

(Dr. S.K. Tomar)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi.