

251

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No. F.6/DFS/MS/NDZ/2021/ 640

Dated: 22/09/2021

To

The Deputy Commissioner (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

**Subject:- Online Application ID No.- 2021081217591 M/s Becon Guest House at Nirman Vihar,
Plot no-6, Veer Savarkar Block, Shakarpur, Delhi-92.**

Sir,

This has a reference to online application ID No.- 2021081217591 dated 25/08/2021 received on the subject cited above. In this connection, it is to inform you that that premises has been re-inspected by the officer concerned of this department on 06.09.2021 in the presence of Mr. Vipin Sharma (G.M) and observed that building comprised of Basement + Ground + 04 upper floor During inspection following shortcomings were observed at site.

1. Exit/Lift signage are not provided.
2. Kitchen activities are still in operation.

In view of the above and as per **gazette notification dated 27.05.2019**, you are directed to submit an **affidavit** in respect of 4th floor **not in use**.

In addition to above the application needs correction in respect of total number of floors, Number of staircase, clear width of staircase, clear width of door, clear width of corridor. Accordingly, the applicant may be directed to furnish correct information and compliance of above shortcomings for further necessary action for renewal of Fire Safety Certificate.

Hence, renewal of FSC cannot be considered at this stage and your online application is rejected.

Yours faithfully,



(Dr. S.K Tomar)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

Mr. Pradeep Kumar,
M/s Becon Guest House,
Nirman Vihar, Plot no-6, Veer Savarkar Block,
Shakarpur, Delhi-92.