

C41

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/EH/2021/SZ/ 415
To

Dated: 23.09.2021

The Dy. Health Officer,
South MCD, South Zone
Green Park, New Delhi 110016.

Sub: Issuance of NOC in r/o M/s Yumcha LLP, 23, Community Centre, Zamrudpur, New Delhi- 110048

Sir,

This has reference to your MHA Portal ID No. 2021071315124 dated 13/07/2021 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 11.09.2021 in the presence of Mr. Chandan Singh to verify the fire safety measures installed in the building and observed that the restaurant is running at Ground plus First floor of the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. There is only one staircase available having width of 1.10 m against the requirement of two having with of 1.50 mtr each from ground to upper floor.
2. There are two doors having width of 1.0 mtr each against the required width of 1.50 mtr each respectively.
3. Overhead tank capacity 5,000 ltrs provided against the required capacity of 20,000 ltrs.
4. Exit Signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to:-

1. M/s Yumcha LLP, 23, Community Centre, Zamrudpur, New Delhi- 110048