

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No.F6/DFS/MS/School/2021/ 37

Dated:- 25/01/2021

To,
The Principal,
Lovely Public Senior Sec. School,
New Layalpur, Delhi-51

Sub:- Renewal of Fire Safety Certificate.

Sir,

With reference to Email ID. lpsssnlp@gmail.com dated 24/12/2020 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Mr. Inder Malik, Principal of the School on dated 11/01/2021. The School building comprises of ground plus three upper floors, three separate blocks A, B & C. During the course of inspection following observations were made:-

1. An overhead water tank having 5,000 liters is required to be provided in each block exclusively for firefighting system.
2. The down comer and hose reel system shall be arranged in such a manner that is should give full coverage (in each block) in accordance with Dte. of Education circular no. 262-362 dated 17/01/05.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,



(Dr. S. K. Tomar)
Dy. Chief Fire Officer



211

Copy to:-

The Dy. Director of Education,
North-East, B-Block,
Yamuna Vihar, Delhi -110053